

Alpine View Estates Static Water Well Measurements

November 18, 2025

To: Vicki Frei

From: Tommy Kuracina

Equipment: Well Sounder 2010 Pro

The static water levels measured varied slightly in all the wells tested.

Lot	Address	Name	Static water level below wellhead pipe	
			11/08/24	11/13/2025
28	3548 Mt Blanc	Baggett	-58.4	-56.5
23	3535 Mt Blanc	Norberg	-31.7	-32.8
26	3521 Mt Blanc	Sanlorenzo	-20.6	-21.5
32	3496 Mt Blanc	Holloway	-35.5	-34.5
93	3464 Alpine View	Minault	-16.5	-18.9
75	3403 Alpine View	Klekar	-5.0	-8.6
67	3440 Bernese	Fawcett	-44.0	-49.2
58	3423 Bernese	Reynolds	-48.9	-52.3
52	449 Bavarian	Rauber	-23.5	-23.6
2	3447 Jacks Valley	Lyche/Clark	-54.5	-55.3
47	3450 Jacks Valley	Fire Station	-85.3	-87.9

Water chemistry at 493 Alpine View Ct., tested on 7/11/24 by Nevada Analytical Services:

Chemistry	Results	Units	EPA Limits
Chloride	2.52	mg/L	250
Nitrate + Nitrate as Nitrogen	1.77	mg/L	10
Sulfate	1.22	mg/L	250
Sodium	25.3	mg/L	-
Potassium	2.07	mg/L	-
Calcium	37.9	mg/L	-
Magnesium	5.32	mg/L	-
Arsenic	ND	mg/L	0.01
Barium	0.07	mg/L	2.00

Copper	ND	mg/L	1.30
Manganese	ND	mg/L	0.30
Zinc	ND	mg/L	0.05
Boron	ND	mg/L	-
Lead	ND	mg/L	0.015

ND = Not Detected